

KARNATAKA POWER TRANSMISSION CORPORATION LIMITED
Corporate Identity Number (CIN) U40109KA1999SGC025521

Phone : 91-080-22274744

E- mail : ceetandp@gmail.com



Office of the
Chief Engineer, Electricity,
Tendering & Procurement, KPTCL
Kaveri Bhavan, 'A' Block,
P.B. No. 9990, BENGALURU – 560 009

No. CEE/T&P/SEE-2/EET12N/ KCO-173/65156/2024-25/

Date: **28 AUG 2024**

OFFICIAL MEMORANDUM

Sub: Inclusion of Vendor approval for supply of 1.1kV Control cables in the approved Vendors list - Reg.

Ref: 1. 87TH VAC meeting proceedings dated:19.01.2024.
2. Vendor Analysis report from CEE(TA&QC) vide letter No. CEE/TA&QC/EE(O)/AEE-2/VAR/F-233/24-25/2511-12 dated:23.05.2024

Approval is accorded for Inclusion of Vendor approval for supply of 1.1kV Control cables of the following Vendor in the approved Vendors list for the materials shown.

Sl. No.	Name of the Firm	Equipment / material	Phone No/ Mobile No.,email
1	M/s. Miracle Cables (India) Pvt Ltd., Office: 1203 Damji Shamji Buisness Galleria, L.B.S Marg, Kanjur Marg (W) Mumbai-400078, Maharashtra, India Works: K-29/2 MIDC, Additional MIDC, Anand Nagar, Opp Bharat Serum, Ambernath(East), Thane-421501, Maharashtra, India	1.1kV LT Copper Control Cables	Ph:+022-25792011/2012 Email:info@miraclecables.com

Terms and Conditions:

- 1) The Vendor approval is conveyed based on the records/ credentials furnished by the Vendor. However Equipments/Materials shall be supplied as per KPTCL Technical specifications duly obtaining approval for relevant drawings, GTP & Type test reports from the competent authorities of KPTCL before offering for inspection. **This approval is valid up to 28.08.2026 and also the approved Vendors shall submit their request for renewal of approval Three months in advance before the expiry of validity.**

- 2) Vendor shall furnish, to the concerned KPTCL Authorities, all the relevant valid type test reports issued by the **CPRI/ERDA** and not older than **10 years**, for the **same** type, rating and voltage class of Equipment/Materials, proposed to supply to the KPTCL projects, during drawing approvals, inspection of equipment/materials etc. The Type test Certificates should be furnished for all the tests conducted as per the relevant IEC/IS/Technical specifications of the equipment/materials proposed to supply to KPTCL project.
- 3) Vendor approvals are considered based on the type test reports of **same/higher** type, rating and voltage class of Equipment/Materials for which vendor approval is requested. However, at the time of inspection of Equipment/Materials by KPTCL officers, Vendors shall invariably furnish, to the concerned KPTCL Authorities, the valid type test reports of not older than **10 years**, issued by **CPRI/ERDA**, for all the tests conducted as per the relevant IEC/IS/Technical specifications, for the **same** type, rating and voltage class of Equipment/Materials as specified in the technical specifications of KPTCL's project and shall obtain approvals for each project, for the Type test reports, QAP, GTPs and drawings of equipments/materials, before offering for inspection.
- 4) In case vendor do not have type test reports for the **same** type, rating and voltage class of materials/ Equipment required for KPTCL, but are having type test reports for **higher** type, rating and voltage class of materials/ Equipment, then such Vendors, **before inspection of Equipment/Materials by KPTCL officers**, shall conduct type tests as per the relevant IEC/IS/Technical specifications of KPTCL on **same** type, rating and voltage class of equipment proposed to supply for KPTCL project at **CPRI/ERDA** in the presence of KPTCL representatives without extra cost to KPTCL and without affecting delivery schedule.
- 5) KPTCL reserves the right to call for any document/credentials for verification during drawing approvals/inspection of materials/equipment by KPTCL authorities, to ascertain the manufacturing experience/performance/technical suitability of the equipment/ materials. Further KPTCL reserves the right to withdraw/ cancel the vendor approval issued, in case vendor fails to furnish valid documents/credentials to KPTCL for verification, supply of poor-quality/defective materials/equipment to the KPTCL projects, poor performance, poor after sales service, deviations in the technical specifications of KPTCL, misleading to the Corporation etc., by the vendors, without prior notice and assigning any reason for such decision.
- 6) Further, vendor shall comply with the qualifying requirements, Terms and Conditions stipulated for the equipments/materials for which empaneled as a vendor and any amendments thereon, during the validity period of this vendor approval.


Chief Engineer (Electy.), 28/8
Tendering & Procurement

Copy to:

1. All the Chief Engineers, Electy., Transmission Zones, KPTCL.
2. The Chief Engineer, Electy, (P&C), KPTCL, Kaveri Bhavan, Bangalore.
3. The Chief Engineer, Electy., (TA & QC), KPTCL, Kaveri Bhavan, Bangalore.
4. The Chief Engineer, Electy, (RT & R&D), KPTCL, Kaveri Bhavan, Bangalore.
5. All the Superintending Engineers (Ele.), W&M Circle, KPTCL, SEE (Tech)/P&M/RT Circles KPTCL.
6. All the Executive Engineers, Elec., Major works/TL&SS Divisions, KPTCL.
7. The Executive Engineer, Elec., T1/T2/P, T&P, Kaveri Bhavan, Bangalore.
8. Above Approved Vendor.
9. MF/OC