



## Maharashtra State Electricity Transmission Company Limited

### Office of The Chief Engineer

Design Department, MSETCL

'Prakashganga', Plot No. C-19, E Block, Bandra - Kurla Complex,  
Bandra (East), Mumbai - 400 051 (Maharashtra) India

**Phone:** (022) 2659 5130 (Direct)  
(022) 2659 5131 (Office)

**E-mail:** cedesign@mahatransco.in

**Website:** www.mahatransco.in

MSETCL / CO / DESIGN / G2 / VENDOR APPROVAL /

07415

DATE: 18 OCT 2024

To,

**M/s MIRACLE CABLE (INDIA) PVT LTD**

Plot No.K-29/2, MIDC, Additional MIDC,  
Anand Nagar, Opp Bharat Serum,  
Ambarnath (East), Dist: Thane-421501

**Sub:** Vendor approval for supply of 1.1 kV, LT, PVC, Control Cable and 1.1 kV, LT, XLPE, Power Cable manufactured by M/s Miracle Cables (India) Pvt. Ltd, Ambarnath Dist: Thane for use in the switchyard of MSETCL Substations against EPC / Turnkey Projects, ORC / DDF Works and Solar / Wind / IPP / Co-generation Projects, etc., thereof...

**Ref:** 1) Your Letter No. MCIPL/24-25/MSETCL/01,dtd:25.06.2024

2) Your Letter No. MCIPL/24-25/MSETCL/02,dtd:10.07.2024 (received in this office on 12.07.2024)

3) Your Email on 28.08.2024.

4) Factory Inspection carried out on 30.08.2024.

Dear Sir / Madam,

1. We refer to above mentioned letters under reference (1) & (2), vide which you have requested this office for incorporation of your firm in list of approved vendors for supply of **1.1 kV, LT, PVC, Control Cable and 1.1 kV, LT, XLPE, Power Cable** for use in the various projects of MSETCL.
2. In this regard, it is to inform that your request for **vendor approval** is accepted by the MSETCL for the supply of **1.1 kV, LT, PVC, Control Cable and 1.1 kV, LT, XLPE, Power Cable** for use in the switchyard of MSETCL Substations against EPC / Turnkey Projects, ORC / DTF Works and Solar / Wind / IPP / Co-generation Projects on the following condition:
  - a. The renewal of approval is valid upto **Three (03) years** from the date of issue of this acceptance letter [**Validity upto: 17.10.2027**].
  - b. This vendor approval is for the works address as mentioned below in this letter and will not apply to any of your branches / offices.


**Work Address - Plot No.K-29/2, MIDC, Additional MIDC,  
Anand Nagar, Opp Bharat Serum,  
Ambarnath (East), Dist: Thane-421501**

- c. Supply of spares / replacement and after sales service, will be valid for at least period of next Ten (10) years from the date of commissioning or Twelve (12) years from the date of supply of equipment / materials whichever is earlier.
- d. Vendor approval shall be applicable to Maharashtra State Electricity Transmission Co. Ltd. (MSETCL) for use in the switchyard of MSETCL Substations against EPC / Turnkey Projects, ORC / DTF Works and Solar / Wind / IPP / Co-generation Projects only.
- e. This vendor approval does not automatically entitle you for getting qualified against the tender floated by our Central Purchase Agency (CPA) Department where stipulated Qualifying Requirement (QR) shall be met by you.
- f. All the raw materials used in the manufacturing of 1.1 kV, LT, PVC, Control Cable and 1.1 kV, LT, XLPE, Power Cable shall be of prime grade and shall be manufactured as per best industry standards. Record for the same shall be produced at the time of inspection of said material.
- g. MSETCL reserves the right to carry out the complete type/routine tests, if warranted on any of the randomly selected sample of 1.1 kV LT PVC Control Cable and 1.1kV LT XLPE Power Cable at NABL Accredited Laboratory in the presence of MSETCL representative, without any cost implication to MSETCL. The tests will be carried out at any time during the period of validity of vendor approval.
- h. MSETCL reserves the right to designate a particular test lab for getting type test done.
- i. You shall arrange for conducting all acceptance tests as per specification of MSETCL, at your works at the time of pre-dispatch inspection, in presence of our representative.
- j. You shall submit the Drawings, Guaranteed Technical Particulars and Manufacturing Quality Plan (MQP) of 1.1 kV, LT, PVC, Control Cable and 1.1 kV, LT, XLPE, Power Cable to this office for approval before commencement of first supply to MSETCL.
- k. You have to maintain high standards of integrity and performance in respect of their supplies and generally endeavor to give no cause for complaints. The quality of material shall not be compromised at any point of time on any grounds what so ever.
- l. You shall always maintain the delivery schedule to avoid time over run of projects.
- m. You are advised to inform us promptly, with necessary supporting documents for any changes in name or ownership or partnership deed or control of the company or address of office / factory or any articles of association or your concern telephone number or e-

mail address, etc. within Thirty (30) days of such change and get approval for the same from this office.

- n. You are requested to apply for renewal, at least Two (02) months prior to the date of expiry of this approval [which is Three (03) years from the date of issuance of this letter]. If you apply after the due date of renewal your application will be treated as a fresh application for vendor approval and not as a renewal application.
  - o. The MSETCL reserves the right to withdraw the vendor approval in case any violation in the design / specification etc., at any given point of time, is brought to the notice.
  - p. If, at any point of time, any abnormality is noticed in regard to any of the above points or performance is found unsatisfactory by any of the office of MSETCL, we reserve the right to withdraw this approval with immediate effect.
  - q. It may please be noted that the responsibility of authenticity of all the relevant photocopies of documents submitted by you for renewal of vendor approval will rest on you. You shall be solely responsible for any dispute / legal issues arising regarding the submitted documents in future. In such case of any dispute, this approval will automatically stand cancelled with immediate effect.
3. You are requested to acknowledge the receipt of this letter.

Regards....



( Kishor Garud )  
Chief Engineer (Design) (I/C)

**Copy s.w.r.to:**

- 1) The Director (Projects)/ (Operations), CO, MSETCL, Mumbai

**Copy f.w.c.to:**

- 1) The Chief Engineer (Projects)/(Trans O &M), CO, MSETCL, Mumbai